

Verification of FCC Door Lock Drops

On May 24th, the FCC emergency weather alert system was upgraded and tied into the newly upgraded fire alarm system. The door locks that needed to drop during a severe weather alert (determined in the Dec. 2010 "Door Lock Drop Tripartite") did drop during the testing of this upgraded alert system. The finding from the tripartite that was noted in frESHTRK was subsequently closed.