

FCC Power Capacity Status

April 12-19, 2010

Tim Kasza



FCC Power Capacity Status

Power Reading From This morning, April 19th

FCC UPS and Building Power

- ▶ Building: 1400A / 1520A (92%)
- ▶ UPS1: 387KVA / 400KVA (98%)
 - 1086A, 1075A, 1064A / 1110A
- ▶ UPS2: 28KVA / 57KVA (49%)
- ▶ UPS3: 85KVA / 95KVA (89%)
- ▶ UPS4: 76KVA / 95KVA (80%)


FCC Power Capacity Status

April 12th - 19th

- ▶ Systems turned on: 2
- ▶ Systems decommissioned: 1
- ▶ Systems on priority wait list to turn on: 16
- ▶ Systems in power OFF status: 44
 - Doesn't include systems off that are possible candidates to move to LCC or GCC, or possible decommission systems
- ▶ Systems scheduled to move: 1 CMS rack, Luster cluster – April 29th to GCC-CRC

FCC Power Capacity Status

April 12th-19th

- ▶ New requests awaiting provisioning of power on UPS1: 12
 - ▶ Estimate of Power usage for 12 new requests
 - ▶ UPS1: ~11 KVA
 - ▶ Next? Identify systems that could relocate to GCC or LCC (FCC Inventory)
- 

FCC Power Capacity Status

April 12th-19th

Questions?

